




**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI - 110001**



No F 6 / DFS / MS / 2023 / School/WZ/ 668

Dated: 21/09/2023

**FIRE SAFETY CERTIFICATE**

Certified that the **Sant Gyaneshwar Model School** located at **Lakhmi Enclave, Extended Lal Dora, Alipur, Delhi-110036** comprised of 02 Blocks (Ground plus two upper floor & Ground plus three upper floors) owned/occupied by **Sant Gyaneshwar Model School**. The premise was inspected by the officer concerned of this department on 15.09.2023 in the presence of Sh. Prem Singh Mann (Chairman) and observed that the fire safety measures are in accordance with rule 33 of the Delhi Fire Service Rules, 2010 have deemed complied and that the building is fit for occupancy class B "Educational building" with effect from 21/09/2023 for a period of **three years**, in accordance with the Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40, subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 21/09/2023 at New Delhi, by

  
(Atul Garg)  
Director  
Ph. 011-23414000

Copy to :-

1. The Director, Education, Old Secretariat, Delhi.
2. The Principal, Sant Gyaneshwar Model School, Lakhmi Enclave, Extended Lal Dora, Alipur, Delhi-36.

**Conditions for the validity of Fire Safety Certificate:**

1. All the fire safety arrangement provided there-in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. This certificate cannot be treated in any case for regularizations of unauthorized construction.
6. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director of Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on

**WWW.dfs.Delhigovt.nic.in**